



# AGA CERTIFIED PRODUCT

Certificate Holder: **BRANDONI SPA**  
ACN No. (if applicable): N/A  
Manufacturer: **Brandoni SpA**  
Agent (if applicable): **Zetco Pty Ltd**  
Type of Component: **Flanged Cast Iron Ball Valve (Type 1)**  
Model No. & Description: **Brandoni & Zetco**  
(Refer [www.aga.asn.au](http://www.aga.asn.au) for more details )

**Brandoni B2.1/Zetco 2601**

**Sizes DN15, DN20, DN25, DN32, DN40, DN50, DN65, DN80, DN100, DN125, DN150 & DN200**

MWP 1600 kPa - with lever handle

**Brandoni B2.1/Zetco 2602**

**Sizes: DN40, DN50, DN65, DN80, DN100, DN125 & DN150**

MWP 1600 kPa - with underground adaptor

**Brandoni B2.1/Zetco 2603**

**Sizes DN25, DN32, DN40, DN50, DN65, DN80, DN100, DN125 & DN150**

MWP 1600 kPa - with lockable lever handle

**Temperature Range: -20°C to 70°C**

Relevant Standard(s): **AS 4617 – 2018 (Incorporating Amdt 1)**

This is to certify that the particular **COMPONENT** specifically described herein and supplied to The Australian Gas Association (hereafter called the AGA) by the Certificate Holder named above has been subject to "type-testing" and assessed by the AGA to comply with the requirements of the AGA's Product Certification Scheme for Type Tested Gas Products.

**This Certificate is issued on the express conditions that:**

- (i) The Certificate Holder undertakes to comply with the Rules Governing The AGA's Product Certification Scheme (hereafter called the Rules Governing);
- (ii) This Certificate remains the property of the AGA; and
- (iii) The AGA reserves the right to cancel this Certificate in accordance with the Rules Governing, and in such an event the Certificate Holder undertakes to surrender the Certificate to the AGA upon request.



**Client Manager**

**Certificate Authorised**

Certificate first issued: **10 September 2004**

Certificate No: **6633**

This copy valid from: **16 December 2021**

Refer specification issue: **07**